

State Water Resources Control Board

June 30, 2015

**CERTIFIED MAIL**  
**NO. 7014 2120 0000 5508 3538**

Mr. Lewis Broschard  
Assistant Chief  
Contra Costa County Fire Protection District  
2010 Geary Road  
Pleasant Hill, California 94523

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS  
LOCATED AT CONTRA COSTA COUNTY FIRE PROTECTION DISTRICT,  
STATION #10, 2955 TREAT BOULEVARD, CONCORD**

Dear Mr. Broschard:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on June 4, 2015, pursuant to authority under Health and Safety Code, chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to Health and Safety Code (H&SC), chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	<b>Failure to Maintain Monitoring Plan</b> - Update UDC monitoring to include a stand-alone sensor in addition to the float and chain assembly listed.	All	June 04, 2015	Ongoing	23 CCR 2711(a)(9)
2	<b>Failure to Maintain Release Response Plan</b> – The form needs to be updated with the correct address and a signature.	All	June 04, 2015	Ongoing	23 CCR 2632(d)(2)
3	<b>Failure to Provide DO Training</b> - The employee training record performed by the DO is dated March 27, 2014.	All	April 1, 2015	Ongoing	23 CCR 2715(f)

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	<b>Failure to Maintain Financial Responsibility</b> – The current financial responsibility form is outdated.	All	June 4, 2015	June 15, 2015	23 CCR 2711(a)(11)
5	<b>Failure to Maintain Facility and Tank Information (A&amp;B Forms)</b> - Update tank installation date and manufacturer on both tanks, piping system is conventional suction for unleaded and diesel dispensers and safe suction for generator. Add generator to the "Tank Use and Contents" section of the diesel tank form.	All	June 4, 2015	June 15, 2015	23 CCR 2711(a)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Contra Costa County Health Services within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

**State Water Board**

Ms. Rebecca Green  
UST Enforcement Unit  
State Water Resources Control Board  
1001 I Street, 19<sup>th</sup> Floor  
Sacramento, California 95814  
[rebecca.green@waterboards.ca.gov](mailto:rebecca.green@waterboards.ca.gov)


**Local CUPA**

Ms. Alexandra McMullen  
Supervising Administrative Support  
Contra Costa County Health Services  
Department  
4585 Pacheco Boulevard, Suite 100  
Martinez, California 94553  
[alexandra.mcmullen@hsd.cccounty.us](mailto:alexandra.mcmullen@hsd.cccounty.us)

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me by telephone at (916) 341-5551, or by email at [amantha.henkel@waterboards.ca.gov](mailto:amantha.henkel@waterboards.ca.gov).

Sincerely,



Amantha Henkel  
Senior Environmental Scientist  
UST Enforcement Unit  
**Office of Enforcement**

cc: (see next page)

cc: *(via email only)*

Ms. Alexandra McMullen  
Supervising Administrative Support  
Contra Costa County Health Services Department  
[alexandra.mcmullen@hsd.cccounty.us](mailto:alexandra.mcmullen@hsd.cccounty.us)

Mr. Adam Springer  
Hazardous Materials Specialist II  
Contra Costa County Health Services Department  
[Adam.Springer@hsd.cccounty.us](mailto:Adam.Springer@hsd.cccounty.us)